



| DIP | Factory setting | function | adjustment |
|-------|-----------------|--------------------------------------|---|
| DIP 1 | OFF | change control unit ancien / nouveau | OFF = control unit 1245181 ON = control unit 1013430 |
| DIP 2 | OFF | room cooling protection | OFF = active ON = inactive |

| Index | Revision | Date | Name | Origin | Replacement for |
|-------|--|------------|---------|----------|-----------------|
| 1 | Averaging with 4 room sensors | 05.09.2016 | Lohe | Checked | 10226 |
| 2 | terminal number clock thermostat changed | 05.12.2016 | Lohe | | |
| 3 | Übersetzung in FR | 05.03.2018 | B.Jaske | Standard | |

KAMPMANN
Genau mein Klima.

Tel: +49 (0) 591 - 7108-0 Fax: 7108-300
E-Mail: info@kampmann.de
Internet: www.kampmann.de

| | | | |
|----------------|--------------|----------------|---|
| Product group | 1.96 | Designation | 2-stage three-phase controller Type 30277 with clock timer and temperature controller |
| Article number | 196000030277 | Project Number | |
| Type | 30277 | Order Number | |
| MAT number | 1245327 | plant: | |
| CAD | 13791 | Page | 1 of 1 |
| | | Location: | |

COPYRIGHT RESERVED - Drawing contains information which has been developed by us and is protected. It must not be made accessible to 3rd persons, competitors in particular, without our prior authorisation. Infringements will lead to a claim for damages !